



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DG-4307AQ1292

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	müller co-ax ag Gottfried-Müller-Straße 1, D-74670 Forchtenberg
Distributor <i>Vertreiber</i>	müller co-ax ag Gottfried-Müller-Straße 1, D-74670 Forchtenberg
Product Category <i>Produktart</i>	gas fittings: Shut-off valve, magnetic/ motor/ pneumatic operated (4307)
Product Description <i>Produktbezeichnung</i>	2/2-way valve, current-free closed, with manual override
Model <i>Modell</i>	MK/FK 15 NC Hd (E/E2)
Test Reports <i>Prüfberichte</i>	supplement test: V-A 1098-06/19 from 26.11.2019 (TSG)
Test Basis <i>Prüfgrundlagen</i>	DIN EN 16678 (01.02.2016)- partially (see remarks)

Date of Expiry / File No. 30.09.2022 / 19-0186-GNV
Ablaufdatum / Aktenzeichen

28.01.2020 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Gas Category <i>Gasart</i>	Remarks <i>Bemerkungen</i>
fuel gases according to G260	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
MK/FK 15 NC Hd (E/E2)	nominal pressure rating: PN 40 nominal diameter: DN 15 ambient temperature range: -15...+80 °C max. operating pressure: 40 bar	

Type Variation <i>Ausführungsvariante</i>	Explanations <i>Erläuterungen</i>
MK 15 NC...	connections: on both sides internal thread G 3/8, G 1/2, G 3/4
FK 15 NC...	connections: both sides flanges DN 15, PN 40

certified Components*zertifizierte Bauteile / Werkstoffe*

Registr. No. <i>Registrier-Nr.</i>	Component <i>Bauteil (Produktart)</i>	Model/Type <i>Modell/Typ</i>	Manufacturer <i>Hersteller</i>
NG-5112AO0744	Sealing material made of elastomers for gas appliances	V 747-75/V 747-75	Parker Hannifin Manufacturing GmbH & Co. KG

Hints of Utilization / Remarks*Verwendungshinweise / Bemerkungen*

Electrical data: optional 24, 48, 60, 98, 110, 125, 200, 220 V DC or 110, 230, 240 V AC, 40-60 Hz

Actuator: electromagnetic, with emergency manual override

Mounting position: any

The inductive proximity switches may only be used for display purposes.

The testing and certification of the manual override was carried out partially according to DIN EN 16678:2016.

